

NOTES:

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION AND ALL OTHER RELEVANT DRAWINGS.
2. THE EXTENT OF WORKS REQUIRED TO COMPLETE THE INSTALLATION IS NOT LIMITED TO THAT SHOWN.
3. INDICATED ROUTES/EXTENTS ARE SHOWN FOR A GUIDE TO INTENDED ROUTES ONLY - FULL CO-ORDINATION BETWEEN ALL PARTIES/SERVICES SHALL BE CARRIED OUT. NO ADDITIONAL COSTS ARE AVAILABLE FOR LACK OF CO-ORDINATION.
4. INDICATED CONTAINMENT IS SHOWN FOR CO-ORDINATION AND GUIDANCE ONLY. SMALL CONTAINMENT I.E. TRUNKING, CONDUIT & TRAY ETC. HAVE NOT BEEN SHOWN FOR CLARITY. THE CONTRACTOR SHALL INCLUDE FOR ALL CONTAINMENT NECESSARY TO INSTALL THE ENTIRE ELECTRICAL INSTALLATION AS PER ALL OTHER DRAWINGS AND SPECIFICATIONS.
5. THE COMPLETE INSTALLATION TO ALL AREAS SHALL IN BE CARRIED OUT IN GALVANISED CONDUIT & GALVANISED STEEL TRUNKING & TRAY, UNLESS STATED OTHERWISE.
6. ONLY FACTORY MADE BENDS, TEES & JOINTS ETC. SHALL BE USED, [FOR BOTH HIGH LEVEL GALVANISED & DADO TRUNKING]
7. THE CONTRACTOR SHALL TAKE FULL COGNISANCE OF THE PRE-TENDER HEALTH AND SAFETY FILE, AND PROVIDE DETAILED METHOD STATEMENTS FOR ALL HAZARDS LISTED THEREIN. ANY WORK SEQUENCE NOT LISTED DEEMED TO BE A HAZARDOUS OPERATION SHALL BE COVERED BY A METHOD STATEMENT FOR ANY ITEM NOT LISTED THEREIN 3 WORKING DAYS PRIOR TO THE COMMENCEMENT OF THIS OPERATION
8. ELECTRICAL CONTRACTOR TO PROVIDE LOCKABLE CUPBOARDS TO HOUSE ALL NEW SWITCHGEAR
9. THE ELECTRICAL CONTRACTOR SHALL SUPPLY TRAFFICITE LABELS DENOTING DIST BOARD OCT REFERENCE ON ALL POWER OUTLETS
10. WHERE HIGH LEVEL GALVANISED OR DADO TRUNKING CROSS STRUCTURAL BEAMS OR COLUMNS THE TRUNKING SHALL BE WORKED AROUND BEAMS AN COLUMNS USING MANUFACTURED BENDS IN ALL CASES.


GENERAL NOTES- APPLICABLE TO ALL DRGS

1. ALL WORKS SHALL BE CARRIED OUT BY A NECEIC APPROVED ELECTRICAL CONTRACTOR
2. THE COMPLETE INSTALLATION SHALL BE INSTALLED, TESTED & COMMISSIONED IN ACCORDANCE WITH THE LATEST EDITION OF IEE WIRING REGULATIONS
3. THE CONTRACTOR SHALL TAKE FULL COGNISANCE OF THE PRE-TENDER HEALTH AND SAFETY FILE, AND PROVIDE DETAILED METHOD STATEMENTS FOR ALL HAZARDS LISTED THEREIN. ANY WORK SEQUENCE NOT LISTED DEEMED TO BE A HAZARDOUS OPERATION SHALL BE COVERED BY A METHOD STATEMENT FOR ANY ITEM NOT LISTED THEREIN 3 WORKING DAYS PRIOR TO THE COMMENCEMENT OF THIS OPERATION
4. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS AND THE SPECIFICATION.
5. EXACT AND FINAL POSITIONS OF ALL EQUIPMENT SHALL BE AGREED ON SITE WITH THE ELEC ENGINEER
6. THE ELECTRICAL CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR CO-ORDINATION OF ELECTRICAL SERVICES WITH OTHER TRADES
7. ALL WIRING MUST BE ENCLOSED IN GALVANISED CONDUIT & GALVANISED STEEL TRUNKING AND RUN TRUE TO BUILDING LINE, UNLESS STATED OTHERWISE
8. MINIMUM SIZE OF CONDUIT TO BE 20mm.
9. BESA BOXES SHOULD BE USED INSTEAD OF BENDS AND TEES IN THE CONDUIT SO AS TO ASSIST IN THE FUTURE INSTALLATION OF CABLES.
10. ALL ACCESSORIES SHALL BE AS MK ALM TYPE OR EQUAL AND APPROVED WHERE SURFACE MOUNTED AND MK WHI TYPE WHERE RECESSED.
11. THE CONTAINMENT SYSTEM FOR OFFICES, MEETING ROOMS, KITCHEN ETC. SHALL BE HIDDEN WITHIN THE BUILDING FABRIC. ALL OTHER AREAS TO BE SURFACE MOUNTED

LEGEND OF SYMBOLS:

- 100MM X 100MM GALVANISED TRUNKING
100MM X 75MM SMALL POWER
100MM X 25MM LV
- DISTRIBUTION BOARD
- 50MM FIRE ALARM TRUNKING
- 200 MM CABLE TRAY FOR HIGH LEVEL LIGHTING
- 150 MM ELV TRUNKING
- SERVICES RISE TO HIGH LEVEL

GROUND FLOOR



P	PRELIMINARY ISSUE	LM	CB	11.13	
Rev	Description	By	Chk	Date	
CLIENT/ARCH					
OMAGH DISTRICT COUNCIL					
CHRISTOPHER BOYLE CONSULTANTS					
36 Carrick Strand, Strabane, Co. Tyrone BT82 9RN					
Tel: 028 7188 2052 Mob. 078 5037 2801					
email: info@cbengineeringconsultancy.co.uk					
Project					
PROPOSED NEW VEHICLE MAINTENANCE FACILLITY					
Drawing Title:					
PROPOSED CONTAINMENT INSTALLATION					
Scale at A1	Drwn By	Date	Chkd By	Date	
1:100	LM	11.13	CB	11.13	
Project No.	Drawing No.			Revision	
1275	1275/15/E401			P	